

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE 1 OF 9 PAGES	
2. AMENDMENT/MODIFICATION NO. 007		3. EFFECTIVE DATE 07/27/2010		4. REQUISITION/PURCHASE REQ. NO. NM-10-01640		5. PROJECT NO. (If applicable)	
6. ISSUED BY  Federal Aviation Administration Acquisition Management Group, ANM-52 1601 Lind Ave SW Renton, WA 98057		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO.	
				<input checked="" type="checkbox"/>		DTFANM-10-R-00045	
				<input type="checkbox"/>		9B. DATED (SEE ITEM 11) 06/15/2010	
				<input type="checkbox"/>		10A. MODIFICATION OF CONTRACT/ORDER NO.	
CODE				FACILITY CODE		10B. DATED (SEE ITEM 13)	

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor ☐ is not, ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

-See page 2 through 4 for changes and clarifications.

-See page 5 through 9 for the attached General Decision to update the Davis Bacon wage rates for this contract.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

I. The above referenced solicitation is amended as follows:

- Receipt of Offers: The date for receipt of offers remains **August 3, 2010**.
- The following changes are made to the Solicitation, Specifications and Drawings:
  - Refer to the Solicitation, Part III – Section J, LIST OF ATTACHMENTS. Replace the *Davis Bacon Wage Rates* General Decision Number: NV20100004 03/12/2010 NV4, with General Decision Number: NV20100004 07/09/2010 NV4. This incorporates the most recent update to the general decision issued by the U.S. DOL (attached).
  - Refer to Drawing G006, Keyed Notes 11, 13, and 15. Delete “25 GA” from these notes.
  - Amendment No. 004, under the heading, "The following changes are made to the Solicitation, Specifications and Drawings:", the first item listed was "Drawing M601 - Add note to Chiller Schedule "Chiller provided with demand limiting or VFD per specifications to accomplish generator sequence". This item shall be revised to read as follows: "Drawing M601 - Add note to Chiller Schedule "Chiller provided with variable frequency drive (VFD) to accomplish demand limiting generator sequence".
  - Amendment No. 005, Question 24, addressed an epoxy coating on carbon steel HVAC piping per Spec Section 23 07 00, Page 17, Para. 3.2.B.1. After further review, the epoxy coating on HVAC piping has been deemed unnecessary and shall be deleted.
  - Refer to Specification Section 28 30 00, E requires the submittal of all Fire Alarm system components be submitted at time of bid. This is incorrect. Submit Fire Alarm data after award.
  - Refer to Specification Section 23 07 00, 3.18 A,B,E,F,M,Q, and R have all supply and return duct being wrapped where as Specification Section 23 31 13 , 3.11 G 1-4 has all supply and return duct being double wall lined. Ducts are to be insulated per the schedule in specification 23 07 00, Para 3.18.
- The following clarifications/revisions are made to the referenced questions in the amendments:
  - Amendment No. 005, Question 144, provides a “control/construction” joint at the bottom of the concrete beam at each of the floor levels on the Base Building (see detail E8/S507). Please note this is to be an architectural reveal only, no cold joint needed unless shown in structural drawings.
  - Amendment No. 004, Question 14: Architectural Elevations of the Parking garage on Drawing A205 detail E7 (South Elevation) indicates concrete walls 8” thick per note 1 between grids 3-4, 5-10. These walls are not shown or called out

on Structural drawing S140. Are walls to be built in these locations? If so please provide details showing the design of these walls with connections to the slab and update the structural drawings.

**Original Answer:** See detail C6/S540 (for first level) and please refer to structural detail A5/S54 (for second level) see also structural plans and building sections.

**NOTE:** Change “SEE SECTION A4, THIS SHEET” at the 2<sup>nd</sup> level, right hand side of section F6/S545, to read “SEE SECTION A5, THIS SHEET”

**Clarification:** See detail C6/S540 (for first level) for walls between columns at grids G3-G4 and G5-G10. Delete the tie beams and thickened edge in the slab on grade between columns at grids G3 –G4 and G5-G6. Also, delete the thickened edge in the slab on grade between column grids G6 –G10. ~~and~~ Please refer to structural detail A5/S54 (for second level) see also structural plans and building sections.

**NOTE:** Change “SEE SECTION A4, THIS SHEET” at the 2<sup>nd</sup> level, right hand side of section F6/S545, to read “SEE SECTION A5, THIS SHEET”

- Amendment No. 004, Question 15: Please provide a detail that shows the connection between the walls shown on S140 at gridlines A, G , 1, and 17 and the columns. Are the walls to tie directly to the columns or should there be an expansion joint between the wall and column. Please clarify.

**Original Answer:** Walls tied to columns, See detail C6/S004.

**Clarification:** ~~Walls tied to columns, See detail C6/S004.~~ Provide 1” expansion joints between the 8” walls and columns or shearwalls. This 1” joint (gap) is shown on detail A6/ S543 for the upper walls, but is intended for the lower walls as well. Seal the joint in lower walls with backer rod and joint sealant for the walls that retain soil.

- Amendment No. 004, Question 17: The concrete formliner that is specified has a maximum depth of .75”. Is this thickness being taken out of the overall structural design thickness for the CIP Walls? Or should the wall thicknesses be increased by .75” in order to accommodate the architectural patterns? Please clarify design intent.

**Original Answer:** The .75” shall not reduce the overall required thickness of the concrete wall thickness defined in documents.

**Clarification:** The .75” depth of formliner is to be taken out of the structural design thickness.

- Amendment No. 004, Question 18: Please furnish a detail for the transition from a formliner surface to a smooth finish surface.

***Original Answer:*** All of the horizontal transitions should occur at a control joint and vertical transitions should occur at corners. The concrete wall thickness to be per structural.

***Clarification:*** All of the horizontal transitions should occur at a control joint or reveal, and vertical transitions should occur at corners. The concrete wall thickness to be per structural.

<<<END OF AMENDMENT>>>

General Decision Number: NV100004 07/09/2010 NV4

Superseded General Decision Number: NV20080004

State: Nevada

Construction Type: Building

County: Clark County in Nevada.

EXCLUDES NEVADA TEST SITE (NTS), NATIONAL TEST AND TRAINING  
RANGE (NTTR) AND TONOPAH TEST RANGE (TTR)

Modification Number	Publication Date
0	03/12/2010
1	03/19/2010
2	06/04/2010
3	07/09/2010

BRNV0013-004 03/01/2009

	Rates	Fringes
BRICKLAYER.....	\$ 34.02	10.20

BRNV0013-005 03/01/2009

	Rates	Fringes
TILE FINISHER.....	\$ 24.04	7.50

BRNV0013-006 03/01/2009

	Rates	Fringes
MARBLE SETTER.....	\$ 35.35	9.75
TILE SETTER.....	\$ 32.92	9.75

\* CARP1780-002 07/01/2010

	Rates	Fringes
CARPENTER (Including Cabinet making and installation, Accoustical Ceiling Installation, Batt Insulation, Drywall Hanging, Form Work, Hardwood Floor Layer and Metal Stud Installation.).....	\$ 37.76	11.10

## Zone Pay:

0 to 40 miles radius from intersection of Maryland Parkway  
and Charleston Blvd in Las Vegas: Free Zone  
40 to 60 miles radius: \$2.50 additional per hour  
Over 60 miles radius: \$4.25 additional per hour  
Laughlin Area: \$2.00 additional per hour

ELEC0357-001 01/01/2010

	Rates	Fringes
ELECTRICIAN.....	\$ 39.99	15.12+3%
SOUND AND COMMUNICATION TECHNICIAN (Alarm		

installation & Low Voltage  
 Wiring).....\$ 39.64 15.12+3%

ZONE PAY:

(A) Free Zone: The area bound by a 25 mile radius from the intersection of Main Street and Fremont Street in Las Vegas.

(B) Add \$2.50 per hour: The area bound by a 25-55 mile radius from the intersection of Main and Fremont Street.

(C) Add \$3.50 per hour: The area outside of a 55 mile radius from Main Street and Fremont Street.

-----  
 ENGI0012-008 07/01/2009

	Rates	Fringes
OPERATOR: Power Equipment		
(03) Skid Loader/Bobcat.....	\$ 37.91	16.00
(04) Base Roller (Ride Along).....	\$ 39.40	16.00
(06) Bulldozer, Forklift and Scraper.....	\$ 39.62	16.00
(08) Mechanic, Paver (Including Asphalt).....	\$ 39.73	16.00
(10) Grader (Finishing and Non-Finishing).....	\$ 39.85	16.00

Add \$1.50 per hour to wage rates:

20 miles to 40 miles from the City Hall of Las Vegas

Add \$2.50 per hour to wage rates:

40 Miles to 60 Miles from the City Hall of Las Vegas

Add \$3.00 per hour:

Over 60 Miles from the City Hall of Las Vegas

-----  
 IRON0118-002 07/01/2009

	Rates	Fringes
IRONWORKER (Ornamental, Reinforcing, and Structural).....	\$ 33.00	23.71

-----  
 LABO0872-004 07/01/2008

	Rates	Fringes
LABORER		
(1) Form Stripping.....	\$ 24.31	16.83
(2) Asphalt Dumpman, Asphalt Shoveler, Cone Setter, Trencher-Hand guided.....	\$ 24.52	16.83
(3) Concrete Saw, Jackhammer, Mason Tender - Brick, Mason Tender - Cement/Concrete, Pipelayer..	\$ 24.62	16.83
(3A) Concrete Vibrator.....	\$ 25.12	16.83
(7) Asbestos Removal (Floor, Wall, Ceiling).....	\$ 25.71	16.83
(8) Flagger.....	\$ 22.81	16.83

-----  
 LABO0872-005 07/01/2008

	Rates	Fringes
--	-------	---------

PLASTER TENDER.....	\$ 25.71	16.83
---------------------	----------	-------

-----

PAIN0159-007 07/01/2009

Rates	Fringes
-------	---------

PAINTER (Including Prep, Brush, Roller, Spray & Drywall Finishing).....	\$ 34.63	11.87
---	----------	-------

-----

PAIN2001-001 01/01/2010

Rates	Fringes
-------	---------

GLAZIER.....	\$ 40.95	16.27
--------------	----------	-------

-----

PLAS0797-001 07/01/2007

Rates	Fringes
-------	---------

CEMENT MASON/CONCRETE FINISHER...	\$ 31.28	11.25
PLASTERER.....	\$ 29.49	11.60

-----

PLUM0525-001 06/01/2009

Rates	Fringes
-------	---------

PIPEFITTER, Including HVAC Pipe Installation.....	\$ 38.15	17.56
--	----------	-------

#### ZONE PAY:

Zone A (Las Vegas)-No Zone Pay  
Zone B (NTS)-Add \$2.00/hour  
Zone C (TTR)-Add \$2.50/hour

-----

SHEE0088-003 01/01/2010

Rates	Fringes
-------	---------

SHEETMETAL WORKER (Including HVAC Duct Installation and Metal Roof).....	\$ 42.81	14.68
--	----------	-------

-----

SUNV2007-002 08/01/2007

Rates	Fringes
-------	---------

LABORER: Common or General.....	\$ 16.49	0.00
---------------------------------	----------	------

LABORER: Landscape.....	\$ 9.85	0.00
-------------------------	---------	------

OPERATOR: Backhoe.....	\$ 16.02	0.00
------------------------	----------	------

OPERATOR: Excavator.....	\$ 17.64	1.45
--------------------------	----------	------

OPERATOR: Loader.....	\$ 23.62	5.10
-----------------------	----------	------

OPERATOR: Trencher, Excluding Hand Guided Trencher...	\$ 27.96	0.00
--	----------	------

PLUMBER, Excluding HVAC Pipe.....	\$ 23.11	0.00
-----------------------------------	----------	------

ROOFER, Excluding Metal Roofs.....	\$ 12.73	3.56
------------------------------------	----------	------

SOFT FLOOR LAYER, Including

Vinyl & Carpet.....	\$ 16.12	1.66
SPRINKLER FITTER (Fire Sprinklers).....	\$ 24.38	0.00
TRUCK DRIVER: Dump Truck.....	\$ 16.57	0.00
TRUCK DRIVER: Water Truck.....	\$ 17.11	2.16

-----  
TEAM0631-003 07/01/2008

	Rates	Fringes
TRUCK DRIVER (Flatbed).....	\$ 26.69	16.64

#### ZONE PAY:

ZONE 1: All work within 30 road miles of City Hall in Las Vegas shall be considered a Free Zone.

ZONE 2: All work 30 to 50 road miles from City Hall in Las Vegas shall receive \$1.50 additional per hour.

ZONE 3: All work 50 to 70 road miles from City Hall in Las Vegas shall receive \$2.50 additional per hour.

ZONE 4: ALL work over 70 road miles from City Hall in Las Vegas shall receive \$3.50 additional per hour.

-----  
WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.  
=====

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29 CFR 5.5(a)(1)(ii)).

-----  
--

In the listing above, the "SU" designation means that rates listed under the identifier do not reflect collectively bargained wage and fringe benefit rates. Other designations indicate unions whose rates have been determined to be prevailing.

-----  
--

#### WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- \* an existing published wage determination
- \* a survey underlying a wage determination
- \* a Wage and Hour Division letter setting forth a position on a wage determination matter
- \* a conformance (additional classification and rate) ruling



On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

END OF GENERAL DECISION